

FIRE SAFETY CERTIFICATE

NO:26/2026

DATE:06.08.2026

Certified that the **VEL'S PUBLIC SCHOOL** (name of the building or premises) at Vels Nagar, Vadakkupudur, sankarankovil.(TK), Tenkasi(DT)(address) Comprised of 1 basements(s) and 2 (upper floors) owned/occupied by **VEL'S PUBLIC SCHOOL, VELS NAGAR, VADAKKUPUDUR** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of state/UT fire Service Rules, and verified by the officers concerned of fire Service on 02.08.2025 (date of inspection) in the presence of **STATION OFFICER Thiru.K.SELVAN** (name and address of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII With effect from 06.08.2026 for a period of **ONE** year in accordance with rule and subject to compliance of specific conditions as appended:

1. Fire extinguisher Should Periodically refilled using fire buckets
2. First aid Kits should be kept ready for emergency use with appropriate medical equipment
3. Chemical used in experiments should be kept safe.
4. Length of staircase should be 1.5 m Footing width of stair should not be less than – 30 cm

Issued on 06.08.2026 (Date of issue) at Vadakkupudur, Sankarankovil(place)by

*Strike out whichever is not applicable.



Signature With Seal:

Name :

Designation :

(Handwritten Signature)
நிலைய அலுவலர்
தீயணைப்பு-மீட்டிங் பணிகள் நிலையம்
சங்கரன்கோவில் - 627 756.

TO

**VEL'S PUBLIC SCHOOL,
VEL'S NAGAR, VADAKKUPUDUR, SANKARANKOVIL(T.K),
TENKASI(DT).**

ENDORSEMENT

The No Objection Certificate issued by Fire Service Stand cancelled and annulled due to

(reasons to be recorded)