

FIRE SAFETY CERTIFICATE

NO: 49 /2024

DATE:06.08.2024

Certified that the **VEL'S PUBLIC SCHOOL** (name of the building or premises) at Vels Nagar, Vadakkupudur,sankarankovil.(TK),Tenkasi(DT)(address) Comprised of **1** basements(s) and **2** (upper floors) owned/occupied by **VEL'S PUBLIC SCHOOL, VELS NAGAR,VADAKKUPUDUR** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of state/UT fire Service Rules,and verified by the officers concerned of fire Service on 05.08.2024 (date of inspection) in the presence of **STATION OFFICER Thiru M.KARUPPIAH** (name and address of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII With effect from 06.08.2024 for a period of **ONE** year in accordance with rule and subject to compliance of specific conditions as appended:

1. Fire extinguisher Should Periodically refilled using fire buckets
- 2.First aid Kits should be kept ready for emergency use with appropriate medical equipment
- 3.Chemical used in experiments should be kept safe.
- 4.Length of staircase should be 1.5 m Footing width of stair should not be less than – 30 cm

Issued on 06.08.2024 (Date of issue) at Vadakkupudur, Sankarankovil(place)by

*Strike out whichever is not applicable.



Signature With Seal:

Name :

Designation :

Station Officer

Fire and Rescue Services

Sankarankovil - 627756

TO

**VEL'S PUBLIC SCHOOL,
VEL'S NAGAR,VADAKKUPUDUR, SANKARANKOVIL(T.K),
TENKASI(DT).**

ENDORSEMENT

The No Objection Certificate issued by Fire Service Stand cancelled and annulled due to

(reasons to be recorded)